

ARMADILLO™ 500R

R-VALUE CALCULATION

Designed by www.cresco-group.com
For more information: www.armadillo-system.com



ARMADILLO™ 500R - R-Values according to the NZS 4218:2006



Wall Thickness mm	Floor Area Perimeter Ratio	ARMADILLO™ 500R R-Value (mK/W)	
		Thermal Base not installed	Thermal Base installed
100	1.5	1.32*	2.10
	2.5	1.76*	2.59
	3.5	2.16	3.05
	4.5	2.56	3.46
150	1.5	1.41*	2.18
	2.5	1.88*	2.71
	3.5	2.31	3.20
	4.5	2.73	3.63
200	1.5	1.48*	2.25
	2.5	1.97	2.80
	3.5	2.43	3.32
	4.5	2.87	3.77
300	1.5	1.60*	2.37
	2.5	2.13	2.96
	3.5	2.62	3.51
	4.5	3.09	3.99

ARMADILLO™ 500R R-Values (with and without ARMADILLO™ Thermal Base installed). The ARMADILLO™ 500R that uses ARMADILLO™ pods 500C has the ARMADILLO™ Thermal Base included as a standard. (*) Configurations not compatible with in-floor heating.

www.armadillo-system.com

R-VALUE FOR WALL 100 mm THICK AND A/p=3.5

GEOMETRY



MATERIALS PROPERTIES

1. Concrete

$$\lambda_1 = 1.6 \frac{W}{m K}$$

Thermal conductivity

$$t_s = 85 \text{ mm}$$

Thickness of slab

$$t_r = 585 \text{ mm}$$

Thickness of rib

2. Cardboard

$$\lambda_2 = 0.21 \frac{W}{m K}$$

Thermal conductivity

$$t_2 = 4 \text{ mm}$$

Thickness of cardboard

$$\epsilon_2 = 0.90$$

Cardboard Emittance

3. Main Air Cavity

$$T = 283K$$

Air Cavity Temperature

$$d_A = 500 \text{ mm}$$

Cavity Thickness

$$d_C = 460 \text{ mm}$$

Cavity Thickness
(with pvc foam)

4. Ground

$$\varepsilon_4 = 0.90$$

Ground Emittance

5. Armadillo Thermal Base

$$\lambda_5 = 0.07 \frac{\text{W}}{\text{m K}}$$

Thermal conductivity

$$t_5 = 6 \text{ mm}$$

Thickness of Armadillo Thermal base

$$\varepsilon_5 = 0.10$$

Emittance

R-Values

$$R_{1s} = \frac{t_s}{\lambda_1} = 0.053 \frac{\text{m}^2\text{K}}{\text{W}}$$

R-value for concrete slab

$$R_{1r} = \frac{t_r}{\lambda_1} = 0.366 \frac{\text{m}^2\text{K}}{\text{W}}$$

R-value for concrete rib

$$R_2 = \frac{t_2}{\lambda_2} = 0.019 \frac{\text{m}^2\text{K}}{\text{W}}$$

R-value for cardboard

$$R_5 = \frac{t_5}{\lambda_5} = 0.086 \frac{\text{m}^2\text{K}}{\text{W}}$$

R-value for Armadillo Thermal Base

$$R_6 = 0.19 \frac{\text{m}^2\text{K}}{\text{W}}$$

R value for air cavity, 40 mm, descending (see table E3 of NZS4214)

Surfaces

$$r = 750 \text{ mm}$$

Distance between Ribs

$$s_w = 600 \text{ mm}$$

Average length of slab

Based on a slab with one side 12 m long and with a Floor Area / Perimeter ratio of 3.5 we have:

$$p_1 = 0.58$$

Percentage of slab

$$p_2 = 1 - p_1 = 0.42$$

Percentage of ribs

Cavity R-Value without Armadillo Thermal Base

$$\sigma = 5.67 \cdot 10^{-8} \frac{\text{W}}{\text{m}^2 \text{K}^4}$$

Stefan-Boltzman Constant

$$\varepsilon_{\text{eff}} = \frac{1}{\frac{1}{\varepsilon_2} + \frac{1}{\varepsilon_4} - 1} = 0.818$$

Effective Emittance

$$h_a = \max \left[0.12 \left(\frac{d_A}{\text{m}} \right)^{-0.44}, \frac{0.025\text{m}}{d_A} \right] \frac{\text{W}}{\text{m}^2\text{K}} = 0.163 \frac{\text{W}}{\text{m}^2\text{K}}$$

$$h_{r0} = 4\sigma T^3 = 5.14 \frac{\text{W}}{\text{m}^2\text{K}}$$

$$h_r = \varepsilon h_{r0} = 4.206 \frac{\text{W}}{\text{m}^2\text{K}}$$

$$R_{3A} = \frac{1}{h_a + h_r} = 0.229 \frac{\text{m}^2\text{K}}{\text{W}}$$

Cavity R-Value

Cavity R-Value with Armadillo Thermal Base

$$\sigma = 5.67 \cdot 10^{-8} \frac{\text{W}}{\text{m}^2 \text{K}^4}$$

Stefan-Boltzman Constant

$$\epsilon = \frac{1}{\frac{1}{\epsilon_2} + \frac{1}{\epsilon_5} - 1} = 0.099$$

Effective Emittance

$$h_{\text{rad}} = \max \left[0.12 \left(\frac{d_c}{\text{m}} \right)^{-0.44}, \frac{0.025\text{m}}{d_c} \right] \frac{\text{W}}{\text{m}^2\text{K}} = 0.169 \frac{\text{W}}{\text{m}^2\text{K}}$$

$$h_{r0} = 4\sigma T^3 = 5.14 \frac{\text{W}}{\text{m}^2\text{K}}$$

$$h_r = \epsilon h_{r0} = 0.508 \frac{\text{W}}{\text{m}^2\text{K}}$$

$$R_{3B} = \frac{1}{h_a + h_r} = 1.477 \frac{\text{m}^2\text{K}}{\text{W}}$$

Cavity R-Value

System R-Values

The R-Value for the system is the weighed average of the R-values of the part with the rib and of the part without ribs.

$$\text{Without Armadillo Thermal Base} \quad R_A = p_1 (R_{1s} + R_2 + R_{3A}) + p_2 R_{1r} = 0.328 \frac{\text{m}^2\text{K}}{\text{W}}$$

$$\text{With Armadillo Thermal Base} \quad R_B = p_1 (R_{1s} + R_2 + R_{3B} + R_5 + R_6) + p_2 R_{1r} = 1.212 \frac{\text{m}^2\text{K}}{\text{W}}$$

To have the R-value of the floor system, the R-value of the Room Air and of The Ground under the slab shall be added.

$$\text{The R-value of the Room Air is} \quad R_a = 0.09 \frac{\text{m}^2\text{K}}{\text{W}}$$

The R-Value of the ground may be taken from Table E6 of NZS 3218:2006, and it depends on Floor Area/Perimeter Ratio and on perimeter wall thickness. For Ratio of 3.5 and a wall thickness of 100 mm, the R-Value is :

$$R_4 = 1.74 \frac{\text{m}^2\text{K}}{\text{W}}$$

The system R-Values are:

$$\text{Without Armadillo Thermal Base} \quad R_{As} = R_A + R_a + R_4 = 2.158 \frac{\text{m}^2\text{K}}{\text{W}}$$

$$\text{With Armadillo Thermal Base} \quad R_{Bs} = R_B + R_a + R_4 = 3.042 \frac{\text{m}^2\text{K}}{\text{W}}$$